



N.T.S.

1. ANY VALVE (WATER OR FORCE MAIN) INSTALLED OUTSIDE OF ASPHALT AREAS MUST BE CONSTRUCTED WITH A 2'x2'x6" CONCRETE COLLAR AROUND IT.

WATER MAIN VALVE

JACKSON TOWNSHIP M.U.A.

NO.	DATE REVISED
5	
4	
3	
2	APRIL 2011
1	MARCH 2010
DRAWN FEB 2003	
SHEET	8 OF 20

