THE JACKSON TOWNSHIP MUNICIPAL UTILITIES AUTHORITY

Ocean County, Jackson Township N.J.

Hyson Backwash Tank Cleaning

Contract No. CT-26239

ADDENDUM NO. 1

11/23/2026

The following, as interpretations, additions, or changes to the Contract Documents will be written into any Contract for the Hyson Backwash Tank Cleaning, Contract No. CT-26239 and must be taken into account in rendering a Bid Proposal for the work.

This Addendum is being provided to all parties of record as having downloaded copies of complete sets of Contract Documents on or prior to the date of this Addendum, through www.jacksonmua.com or directly from www.questcdn.com by inputting Quest Project No. 10445163 on the website's Project Search page. (Please contact QuestCDN.com at 952 233-1632 or info@questcdn.com for assistance in free membership registration, downloading, and working with this digital project information.)

Prospective Bidders and all concerned are hereby informed that the following changes are made as part of the Contract Documents and are requested to amend all documents to include the following accordingly:

A. Date of Bid Opening:

The bid opening Date shall be changed from December 1, 2026 at 2:00 to December 11, 2026 at 2:00.

B. Questions & Answers

- **How many tanks are included under this contract? 3**
- **Size and tank elevations for each tank? Approximately 30' height, 30' diameter. There is a hatch at the top with ladder access and a manway about 4' above ground level. Tanks will be drained to level of manway.**
- **Please provide drawings of the tanks, if available.**
- **Quantity and type of sludge to be removed for each tank? Iron sludge (ferric). Quantity unknown. Guess approximately 15000 gallons**
- **Can you provide latest analysis report of the sludge? No actual sludge quality analysis report. However, see attached report concerning liquified sludge that leaves the tanks during wasting process.**
- **When were the tanks last cleaned? Approximately 5 years ago.**

END ADDENDUM NO. 1