



NOTE: LOCATION OF SERVICE CONNECTION & CLEANOUT SHALL BE DETERMINED IN THE FIELD TO COMPLY WITH REQUIREMENTS OF THE PROPERTY OWNER & M.U.A. CLEAN-OUT IS NOT PERMITTED IN DRIVEWAY OR SIDEWALK. IT SHALL BE INSTALLED BETWEEN THE CURB AND THE SIDEWALK. SHOULD NO CURBING EXIST A 2' X 2' X 6" CONCRETE COLLAR IS REQUIRED TO BE CONSTRUCTED.



Title **DEEP HOUSE SERVICE LATERAL**

**JACKSON TOWNSHIP
MUNICIPAL UTILITIES AUTHORITY**

135 Manhattan St., Jackson, NJ 08527 732-928-2222 www.jacksonmua.com

DRAWING No.	No.	Date	REVISION
03	May 22, 2018	NEW TITLE BLOCK AND NOTES	
02	April 2011		
01	March 2010		
No.	Date	REVISION	
Date	FEB 2003	Scale	N.T.S.
Revised By	JSD		