

PRIOR TO INSTALLATION:

- ✓ METERS CANNOT BE INSTALLED IN CRAWL SPACES, BEHIND APPLIANCES, HOT WATER HEATERS OR FURNACES.
- ✓ THERE MUST BE A MINIMUM CLEARANCE OF 12" ON EACH SIDE OF THE METER AND A MAXIMUM OF 36" ABOVE THE FLOOR

IN ADVANCE OF THE PROJECTED INSTALLATION DATE, CONTACT CUSTOMER SERVICE:

- ✓ AN APPLICATION FOR SERVICE MUST BE COMPLETED.
- ✓ APPLICABLE CONNECTION FEES MUST BE PAID IN ACCORDANCE WITH THE CURRENT 'SCHEDULE OF RATES'.
- ✓ AN APPOINTMENT IS SCHEDULED FOR WATER METER INSTALLATION, GRANTED ALL CONNECTION FEES HAVE BEEN SATISFIED.
- ✓ ALL METERS ARE SUPPLIED BY THE AUTHORITY. (METERS 1 1/2 INCHES OR LARGER ARE INSTALLED BY THE CONTRACTOR BUT INSPECTED BY AUTHORITY PERSONNEL. METERS SMALLER THAN 1 1/2 INCHES WILL BE INSTALLED BY AUTHORITY PERSONNEL.)


AT THE TIME OF THE INSTALLATION:

- ✓ CURB STOPS AND SEWER CLEAN-OUTS ARE NOT PERMITTED IN DRIVEWAYS OR SIDEWALKS AND MUST BE SET TO GRADE BEFORE THE METER CAN BE INSTALLED.
- ✓ A TUB AND/OR SINK MUST BE INSTALLED IN ORDER TO FLOW TEST THE METER.
- ✓ NEW CONSTRUCTION MUST HAVE HEAT.

**NOTE:** IF THE METER SPREAD OR OTHER REQUIREMENTS ARE NOT MET, AN ADDITIONAL FEE, IN ACCORDANCE A SECOND INSTALLATION IS ATTEMPTED.

AFTER THE INSTALLATION:

- ✓ ONCE THE AUTHORITY HAS DETERMINED THAT THE METER HAS BEEN SUCCESSFULLY INSTALLED AND TESTED, CUSTOMER SERVICE WILL ISSUE A LETTER OF COMPLIANCE FOR PRESENTATION TO THE TOWNSHIP.

	Title	SINGLE WATER METER	DRAWING No.	03	May 15, 2018	NEW TITLE BLOCK	
	<b>JACKSON TOWNSHIP MUNICIPAL UTILITIES AUTHORITY</b>			02	April 2011		
				01	March 2010		
			No.	Date	REVISION		
	135 Manhattan St., Jackson, NJ 08527 732-928-2222 www.jacksonmua.com		Date	FEB 2003	Scale	N.T.S.	Revised By